

From: [Rodriguez, Jose](#)
To: [Fred Black](#)
Subject: RE: Cochiti Lake
Date: Thursday, July 16, 2015 10:38:00 AM

Good Morning Fred,

Thank you for following up on this. I do have the information for the backup well (Golf Course Well).

Thank you,

Jose

-----Original Message-----

From: Fred Black (b(6))
Sent: Thursday, July 16, 2015 10:16 AM
To: Rodriguez, Jose
Subject: Re: Cochiti Lake

Good morning Jose, I called Pete last night and he will send me photos with that info. I assume you have the backup well info. It was 200 hasp at 500gpm. I'll get that information over to you as soon as I get it.

Sent from my iPad

On Jul 15, 2015, at 9:58 AM, "Rodriguez, Jose" <Rodriguez.Jose@epa.gov> wrote:

> Good Morning Fred,

>

> I have a question about the Cochiti Lakes Water System booster pumps. Would you happen to know the size of the pumps. I have that the main pump is 500 GPM and 75 HP but do not have any information on the back up pump. If you have that information could you please provide it to me.

>

> Thank you,

>

> Jose

>

> -----Original Message-----

> From: Fred Black (b(6))
> Sent: Monday, May 18, 2015 2:39 PM
> To: BakerJohnE@epa.gov
> Cc: Rodriguez, Jose
> Subject: Cochiti Lake

>

> Good catch, this is tank 1, next to the well house . The other one was correct .

>